



















Damage caused by incorrect lifting is the responsibility of others

- Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at
- Specify any specific requirements prior to ordering. All civil works by customer
- Do not scale from this drawing. Only for illustration purposes

Title: 2L tanks pump station

Volume: 20,000 litres

Usable volume: 14,200 litres

Drg. no.: PS-L-064-130520

Date: 13/05/2020

Drawn by: SF